

## TEST AND RANGE CLASSIFICATION SIMPLIFIED REPORT REPORT Nº : P-25-27427/6/I

GAIKER Foundation notifies that the flame retarded plywood boards range supplied for testing by:

**Grupo Garnica Plywood, S.A.U.**

**Parque San Miguel, 10 bajos. 26007 Logroño La Rioja (Spain).**

with range trade reference:

**Fireshield**  
**THICKNESS BETWEEN 8 mm and 40 mm**  
**(BOTH INCLUDED)**

Obtains the following classification a/t EN 45545-2:2020 + A1:2023:

Requirement	Hazard level
<b>R10</b>	<b>HL1, HL2 and HL3</b>

These classifications are the result of the data included in the reports P-25-27427/1/I, P-25-27427/2/I, P-25-27427/3/I, P-25-27427/4/I and in the range classification report P-25-27427/5/I, all of them made by GAIKER between 14th/04/2025 and 12th/05/2025.

Classification obtained following the simple binary acceptance decision rule. This decision rule, according to ILAC-G8:09 guide, leads to the following specific risk: probability of false acceptance or probability of false rejection is less than 50%.